

**TOWN OF FORT FRANCES
OPERATIONS AND FACILITIES DIVISION
TRENCHLESS RELINING OF WAERMANS**

TENDER NO. 21-OF-09

ADDENDUM #1

May 11, 2021

This addendum addresses errors, omissions or questions noted to May 11, 2021 pertaining to Tender# 21-OF-09. The information contained within form part of the Tender documents and amends the original specifications.

Firms shall acknowledge receipt of this addendum in their proposal.

1. Section 3 shall be amended by adding the following:
3.3 The primary failure mechanism of these mains has been through failure at the two bolt joint connections. The proposed lining shall be such that a joint failure will not result in a lining failure.
2. Section 5.1.6 shall be removed and replaced with the following:
The liner shall meet a minimum AWWA Class III semi-structural liner specifications.

END OF ADDENDUM #1